

# FRAMING NULM-GH

FLAN HILLS CORPORATION • IRVINE, CALIFORNIA  
GREENPAPER BY NUMBERS EDITION

1. Thermometers for piping shall be of the "all angle" (universal), separate socket, industrial type with #304 stainless steel extension neck wells.
2. The thermometer for auxiliary cooling shall operate at 0 - 160 Deg. F range and shall include a sufficient safety margin at either end.
3. Thermometers shall be as manufactured by Albert A. Weiss, Weksler Instrument Co., Ashcroft or approved equal.